

**ATTACHMENT 3**  
**PLATFORM ELLEN**  
**NON-CONTACT COOLING WATER CHLORINE RESULTS**  
**July 1, 2020 through September 30, 2020**

<u>Discharge</u>	<u>Measurement Frequency</u>	<u>Average Monthly Limit <sup>1</sup> Post Dilution</u> (mg/l)	<u>Maximum Daily Limit <sup>1</sup> Post Dilution</u> (mg/l)	<u>Result Post Dilution</u> (mg/l)	<u>End-of-Pipe Concentration</u> (mg/l) EPA Method 330.5	<u>EPA Plumes Dilution</u>
009 Non-contact Cooling Water Sample Date: 09/29/20	Once/Quarter	0.00583	0.0104	0.0013	0.20	149:1

<sup>1</sup> Limits are post-dilution as listed in Appendix C of the Permit.